

PLEASE CHECK WWW.MOLEX.COM FOR LATEST PART INFORMATION

Part Number:

19131-0003

Status:

Active

Description:

InsulKrimp™ Block Spade Tongue Terminal for 10 to 12 AWG Wire, Stud Size 8 (M4), Length 27.31mm

Documents:

Drawing (PDF)

Product Specification PS-19902-009 (PDF)

Product Specification PS-19902-011 (PDF)

Product Specification PS-19902-015 (PDF)

RoHS Certificate of Compliance (PDF)

Agency Certification

CSA

LR18689

UL

E32244

General

Product Family

Ring and Spade Terminals

Series

19131

Crimp Quality Equipment

Yes

Mil-Spec

N/A

Product Name

InsulKrimp™

Type

Spade Block

UPC

800753101265

Physical

Barrel Type

Closed

Color - Resin

Natural

Flammability

94V-0

Insulation

PVC

Material - Plating Mating

Tin

Net Weight

1.840/g

Packaging Type

Adhesive Tape on Reel

Stud Size

8 (M4)

Termination Interface: Style

Crimp or Compression

Wire Insulation Diameter

6.40mm max.

Wire Size AWG

10, 12

Wire Size mm²

3.30 - 5.00

Material Info

Old Part Number

C-2105-08XT

Reference - Drawing Numbers

Product Specification

PS-19902-009, PS-19902-011, PS-19902-015

Sales Drawing

CCD20301




image - Reference only

Series

EU RoHS

ELV and RoHS

Compliant

REACH SVHC

Not Reviewed

Low-Halogen Status

Not Low-Halogen

China RoHS



Need more information on product environmental compliance?

Email productcompliance@molex.com
For a multiple part number RoHS Certificate of Compliance, [click here](#)

Please visit the [Contact Us](#) section for any non-product compliance questions.

Search Parts in this Series
19131Series

Application Tooling | FAQ
Tooling specifications and manuals are found by selecting the products below. Crimp Height Specifications are then contained in the Application Tooling Specification document.

Global Description	Product #
Crimp Dies for MTA-100 Tape Applicator used in 3BF Press, MTA-105 Tape Applicator used in TM-2000™ Press, and ATP-301 Air Crimping Press for Mylar Tape Mounted Terminals Mini-Mac™ Applicator	0192880179
	0638851500

This document was generated on 10/22/2013

PLEASE CHECK WWW.MOLEX.COM FOR LATEST PART INFORMATION